

**Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar**

**The Principal
Delhi Public School
Nagbani, Jammu**

No: DFES-FP/9/2022-04(CC-7079422) 472


Dated: 20.03.2023


Sub: Fire Safety Certificate.


Ref: Your online application submission dated: 10.02.2023 (FI-624997).


The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed 03 Nos. of Hose Reel Hoses and 08 Nos. of First Aid Fire Extinguishers in their school premises. The school is about 04 Km away from Fire and Emergency Station Canal (Lower Muthi) and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such, the management can proceed ahead for operation subject to adopt the following fire safety measures/guidelines in letter and spirit forthwith:-

1. 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
2. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. Fixed/First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling / operating of fire fighting system installed in the school building. The management shall intimate this office in writing after each quarter that the fire fighting equipments installed in the school are functioning.
4. All electric installations existing in the building should be concealed conduit type.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. The corridor of the building shall not be used for any kind of storage.
7. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
8. An emergency exit should be provided in double storey block for safe evacuation of students/staff in case of any emergency.
9. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is having two blocks, one is double storey and another is single storied. As such no addition / alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
11. The department can made a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
12. This clearance shall be subject to outcome of any dispute/investigation/enquiry/ trial if any, pending before any Court of Law/investigation agency. This clearance shall not confirm any title upon the person/company in whose favour it is issued.
13. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school building. However, before granting permission/recognition/ extension or renewal thereof, the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010, issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.


Principal
DELHI PUBLIC SCHOOL
Nagbani, Jammu (West)


Secretary
Maharaja Hari Singh
Social and Education
Foundation Trust, J&K


Director
Fire & Emergency Services, J&K
Jammu/Srinagar


Director
DELHI PUBLIC SCHOOL
Nagbani, Jammu (West)